


Direct Reading Instrumentation Weekly Summary

10/12/16 6:00 – 10/19/16 6:00

Sampling Location –A & AP-Tank Farms (map below)



This summary contains Vapor Monitoring and Detection System (VMDS) pilot-scale data collected over one week (October 12th at 6:00 a.m. through October 19th at 6:00 a.m.) using direct reading vapor detection instruments. Pilot-scale testing is focused on evaluating component integration and functionality. Data shown may include results for calibration and calibration check (bump test) tests performed to verify sensors are functioning; these tests are visible in the data as spikes. Any direct reading instrument alarms occurring during Phase 1 pilot-scale testing are taken to be actual events and the appropriate actions/notifications are taken.

Abbreviations:

- NH₃ = ammonia
- CO = carbon monoxide
- CO₂ = carbon dioxide
- LEL = lower explosive limit
- NO = nitric oxide
- N₂O = nitrous oxide
- NO₂ = nitrogen dioxide
- VMDS = Vapor Monitoring and Detection System
- VOC = volatile organic compounds, which include both volatile and semi-volatile compounds.

Direct Reading Instrumentation Weekly Summary

10/12/16 6:00 – 10/19/16 6:00

Weekly Summary: The AreaRAE instruments were down due to communication issues. ToxiRAE and MultiRAE instruments are personal monitors and were not in used during this time period.

Note that instrument tags (labels) reported in OSI PI and often presented in weekly summary information are captured directly from OSI PI and that all gas monitoring instruments begin with 200-GM, followed by the target analyte (such as NH₃), followed by the instrument type (three digit number), and the instrument unit as sequential letters. For example, "200-GM-NH3-512C" is an ammonia sensor reporting from Gastronics' (denoted as "512") instrument "C".

Gastronics N₂O sensors continue to show very sharp spikes, often to full scale. The 512G N₂O sensor exhibited a recurring pattern early morning which could be caused by atmospheric conditions. Four Gastronics instruments reported VOCs > 1 ppm with instrument 512F exhibiting a spike to 21 ppm over several minutes. The spike occurred Sunday evening when no personnel were in the tank farm. Unit 512Q again showed a recurring pattern on three separate days where values increased over a several hour period before peaking and decreasing. The highest VOC peak measured by 512Q was 6.9 ppm. This pattern appears to correspond to increasing and decreasing relative humidity and is being further investigated. Further review of the data and information on VOC detections by the Gastronics FIS instruments determined that the VOC photoionization detector (PID) lamps are overdue for cleaning and maintenance. Additional lamps have been ordered to switch out for existing lamps during cleaning. However, until this is accomplished, the elevated values are considered questionable. A total VOC limit of 2 ppm currently is employed by the Industrial Hygiene Program Technical Basis¹.

¹ RPP-22491, Rev 1, "Industrial Hygiene Chemical Vapor Technical Basis": <http://hanfordvapors.com/wp-content/uploads/2016/10/Industrial-Hygiene-Chemical-Vapor-Technical-Basis-RPP-22491 - Rev 1.pdf>

Direct Reading Instrumentation Weekly Summary

10/12/16 6:00 – 10/19/16 6:00

October 5th – October 12th 2016 Observations By Instrument:

HazScanner (501) – The HazScanners, 501A and 501B, have not been calibrated, and work is ongoing to complete their configuration. Therefore no data is presented from these instruments – other than up-time.

AreaRAE (502) – Not reporting during this week.

Table 1. AreaRAE Comments.

| Compound (units) | Comment | OEL | Action Level | Detection Range |
|-----------------------|-------------------|-----|--------------|-----------------|
| CO (ppm) | No data reported. | 50 | 25 | 1 – 500 |
| LEL (%) | No data reported. | | | 0 – 100 |
| NH ₃ (ppm) | No data reported. | 25 | 12.5 | 1 – 50 |
| Oxygen (%) | No data reported. | | <19.5 | 1 - 30 |
| VOC (ppm) | No data reported. | | 2 | 1 - 200 |

ToxiRAE (503) – Not used during this week.

Table 2. ToxiRAE Comments.

| Compound (units) | Comment | OEL | Action Level | Detection Range |
|------------------|-------------|-----|--------------|-----------------|
| VOC (ppm) | Not in use. | N/A | 2 | 0.1 - 2000 |

MultiRAE (504) – Not used during this week.

Table 3. MultiRAE Comments.

| Compound (units) | Comment | OEL | Action Level | Detection Range |
|-----------------------|---|-----|--------------|-----------------|
| CO (ppm) | A – Not in use. B – Not in use. C – Not in use. | 50 | 25 | 0 – 500 |
| LEL (%) | A – Not in use. B – Not in use. C – Not in use. | N/A | | 0 – 100 |
| NH ₃ (ppm) | A – Not in use. B – Not in use. C – Not in use. | 25 | 12.5 | 1 – 500 |
| Oxygen (%) | A – Not in use. B – Not in use. C – Not in use. | | <19.5 | 1 – 30 |
| VOC (ppm) | A – Not in use. B – Not in use. C – Not in use. | N/A | 2 | 0.1 – 5000 |

Direct Reading Instrumentation Weekly Summary

10/12/16 6:00 – 10/19/16 6:00

RAE MeshGuard (505) – Ammonia detection instruments deployed primarily in A Tank Farm with units also deployed to AP Tank Farms.

Table 4. RAE MeshGuard Comments.

| Compound (units) | Comment | OEL | Action Level | Detection Range |
|-----------------------|---|-----|--------------|-----------------|
| NH ₃ (ppm) | Instruments reporting: A, C, D, F, J, K, M, N, O, P, Q, R, S, T, V, X, and Y. <ul style="list-style-type: none"> • No ammonia detected. • Calibration tests on: A, C, D, F,G, H, I, J, K, L, M, N, O, P, Q, R, S, T, U, V, W and X. | 25 | 12.5 | 1 – 50 |

FIS-Gastronics (512) – Monitor for ammonia, volatile organic carbon, and nitrous oxide.

Table 5. Gastronics Comments.

| Compound (units) | Comment | OEL | Action Level | Detection Range |
|------------------------|--|-----|--------------|-----------------|
| NH ₃ (ppm) | No ammonia reported on any instrument (other than calibration tests) <ul style="list-style-type: none"> • Calibration/check tests performed on A, D, E, F, H, I, K, M, N, P, T, U, X, and Y. | 25 | 12.5 | 1 – 500 |
| VOC (ppm) | <ul style="list-style-type: none"> • Calibration/check tests performed on A, D, E, F, H, I, K, M, N, T, U, X, and Y. Instruments A, D, S, and Y report 10x actual values. • Instruments reporting no detection of VOCs: E, H, and T • Instruments that reported a non-zero value of < 2 ppm: A, D, G, I, K, M, N, P, S, U, X and Y • Instruments reporting maximum values ≥ 2 ppm: F (21 ppm) and Q (6.9 ppm). <ul style="list-style-type: none"> ○ 512Q continued to show a recurring pattern on three separate days (graph below) | N/A | 2 | 0 – 1000 |
| N ₂ O (ppm) | N ₂ O sensors only reporting from 512 E, F, G, H, I, K, M, N, O, P, Q, T, and U. <ul style="list-style-type: none"> • Below detection levels on A, D, H, I, K, M, O, P, Q, T, and U • A, D, M, O, P, Q, T, and U reported only for brief periods • Spikes to full scale reported on E and G. • F reported values up to 993 ppm and N reported values up to 412 ppm (see figure) | 50 | 25 | 0 – 1000 |

Direct Reading Instrumentation Weekly Summary

10/12/16 6:00 – 10/19/16 6:00

Figure 1. Gastronics VOC; Greater Than the Action Limit or Recurring Pattern.





Figure 2. Gastronics N₂O; Recurring Pattern on 512G.



Direct Reading Instrumentation Weekly Summary

10/12/16 6:00 – 10/19/16 6:00

October 12th – October 19th 2016 Instrument Operational Status:

Time reporting is calculated using the average time sensors are reporting to OSI PI² for each instrument:

Table 6. HazScanner (501) % Time Reporting by Instrument.

| Instrument | % Time Reporting | Instrument | % Time Reporting |
|------------|------------------|------------|------------------|
| 501A | 0 | 501B | 70 |

Notes: a) % time reporting is estimated on review of graphs from OSI PI.

Table 7. AreaRAE (502) % Time Reporting by Instrument.

| Instrument | % Time Reporting | Instrument | % Time Reporting | Instrument | % Time Reporting | Instrument | % Time Reporting |
|------------|------------------|------------|------------------|------------|------------------|------------|------------------|
| 502A | 0 | 502D | 0 | 502G | 0 | 502J | 0 |
| 502B | 0 | 502E | 0 | 502H | 0 | | |
| 502C | 0 | 502F | 0 | 502I | 0 | | |

Notes: a) % time reporting is estimated on review of graphs from OSI PI.

Table 8. ToxiRAE (503) % Time Reporting by Instrument (personal monitors only used when operators are in the field).

| Instrument | % Time Reporting | Instrument | % Time Reporting | Instrument | % Time Reporting |
|------------|------------------|------------|------------------|------------|------------------|
| 503A | 0 | 503E | 0 | 503I | 0 |
| 503B | 0 | 503F | 0 | 503J | 0 |
| 503C | 0 | 503G | 0 | 503K | 0 |
| 503D | 0 | 503H | 0 | | |

Notes: a) % time reporting is estimated on review of graphs from OSI PI.

Table 9. MultiRAE (504) Time Reporting by Instrument (personal monitors only used when operators are in the field).

| Instrument | % Time Reporting | Instrument | % Time Reporting | Instrument | % Time Reporting |
|------------|------------------|------------|------------------|------------|------------------|
| 504A | 0 | 504B | 0 | 504C | 0 |

Notes: % time reporting is estimated on review of graphs from OSI PI.

² OSI PI is a data visualization software package from [OSIsoft](http://OSIsoft.com).

Direct Reading Instrumentation Weekly Summary

10/12/16 6:00 – 10/19/16 6:00

Table 10. RAE MeshGuard (505) % Time Reporting.

| Instrument | % Time Reporting | Instrument | % Time Reporting | Instrument | % Time Reporting | Instrument | % Time Reporting |
|------------|------------------|------------|------------------|------------|------------------|------------|------------------|
| 505A | >95 | 505H | 0 | 505O | >95 | 505V | >95 |
| 505B | 0 | 505I | 0 | 505P | >95 | 505W | 0 |
| 505C | >95 | 505J | >95 | 505Q | >95 | 505X | >95 |
| 505D | >95 | 505K | 20 | 505R | 70 | 505Y | 80 |
| 505E | 0 | 505L | 0 | 505S | 10 | | |
| 505F | >95 | 505M | >95 | 505T | >95 | | |
| 505G | 0 | 505N | >95 | 505U | 0 | | |

Notes: a) % time reporting is estimated on review of graphs from OSI PI.

Table 11. Gastronics (512) % Time Reporting by Instrument.

| Instrument | % Time Reporting | Instrument | % Time Reporting | Instrument | % Time Reporting | Instrument | % Time Reporting |
|------------|------------------|------------|------------------|------------|------------------|------------|------------------|
| 512A | >95 | 512H | >95 | 512N | 30 | 512T | >95 |
| 512B | 0 | 512I | >95 | 512O | 0 | 512U | >95 |
| 512C | 0 | 512J | 0 | 512P | >95 | 512V | 0 |
| 512D | >95 | 512K | >95 | 512Q | >95 | 512W | 0 |
| 512E | >95 | 512L | 0 | 512R | 0 | 512X | 80 |
| 512F | >95 | 512M | >95 | 512S | <5 | 512Y | 80 |
| 512G | >95 | | | | | | |

Notes: a) % time reporting is based on review of graphs from OSI PI for NH₃ sensors.